

# TILE INSTITUTE of AMERICA

1262 Bouquet Circle, Thousand Oaks, California 91362 Telephone: (805) 371-TILE (8453) Facsimile: (805) 371-8453  
23825 15<sup>th</sup> Avenue SE #110, Bothell, Washington 98021 240 Makee Road, Suite PH-A, Honolulu, Hawaii 96815  
[DoctorTile@aol.com](mailto:DoctorTile@aol.com) [DoctorTile1@gmail.com](mailto:DoctorTile1@gmail.com) (805) 444-8453

TIA's Client: 20201228 BS

**Aquabella USA, LLC**  
**Mr. Brian L. Streadbeck**  
**450 South Alpine Highway**  
**Alpine, Utah 84004**

Telephone: (833) 985-2955  
[info@aquabellatile.com](mailto:info@aquabellatile.com)

Tile: **Harmony / Reminiscing Series**

HM-106 - COBALT BLUE 1X1	HM-141 - BAHAMAS BLUE 1X1	HM-210 - ROYAL BLUE 2X2	HM-310 - SAPPHIRE 3X3
HM-109 - BLACK 1X1	HM-143 - ALT BLUE 1X1	HM-213 - TERRA BLUE 2X2	HM-313 - TERRA BLUE 3X3
HM-110 - ROYAL BLUE 1X1	HM-144 - PACIFIC BLUE 1X1	HM-220 - ELECTRIC BLUE 2X2	HM-320 - ELECTRIC BLUE 3X3
HM-113 - TERRA BLUE 1X1	HM-145 - MALIBU BLUE 1X1	HM-305 - MARBLED BLUE 3X3	HM-340 - NAVY BLUE 3X3
HM-120 - ELECTRIC BLUE 1X1	HM-205 - MARBLED BLUE 2X2	HM-306 - COBALT BLUE 3X3	RM-130 - BISCAYNE BAY 1X1
HM-124 - SKY BLUE 1X1	HM-206 - COBALT BLUE 2X2	HM-105 - MARBLED BLUE 1X1	RM-132 - BLUE PEARL 1X1
HM-140 - NAVY BLUE 1X1	HM-209 - BLACK 2X2	HM-309 - BLACK 3X3	

Conditions: New tiles were sent to TILE INSTITUTE of AMERICA in sealed manufacturer's boxes from client above and selected at random.

## TEST CONDUCTED:

### Resistance of Tile to Chemical Substances (ASTM C650)


**Procedure:** This test method covers a procedure for determining whether, and to what degree, tiles are affected by prolonged exposure to chemical substances (10% Hydrochloric Acid & 10% Potassium Hydroxide). The temperature was controlled at 75±5 ° F (24±3 ° C) with an exposure time of 24 hours.

**Requirements:** ANSI A 137.1 (General). When tested as described in ASTM C 650, the Tile shall Not be affected.

The tile types and categories listed above yielded test values compliant with Industry's requirements.

Test Results: **Passed**

Sincerely,

A handwritten signature in black ink that reads "Gerald M. Halweg". The signature is written in a cursive style with a large, sweeping initial "G".

Gerald M. Halweg, CTC, CSI, TTA. Date: July 1, 2021  
President/CEO of TILE INSTITUTE of AMERICA