



# ◆ **TILE INSTITUTE of AMERICA** ◆

1262 Bouquet Circle, Thousand Oaks, California 91362 Telephone: (805) 371-TILE (8453) Facsimile: (805) 371-8453  
 23825 15<sup>th</sup> Avenue SE #110, Bothell, Washington 98021 240 Makee Road, Suite PH-A, Honolulu, Hawaii 96815  
[DoctorTile@aol.com](mailto:DoctorTile@aol.com)    [DoctorTile1@gmail.com](mailto:DoctorTile1@gmail.com)    [\(805\) 444-8453](tel:(805)444-8453)

TIA's Client: 20201228 BS

**Aquabella USA, LLC**  
**Mr. Brian L. Streadbeck**  
**450 South Alpine Highway**  
**Alpine, Utah 84004**

Telephone: (833) 985-2955  
[info@aquabellatile.com](mailto:info@aquabellatile.com)

Tile: **Harmony Series**

HM-106 - COBALT BLUE 1X1	HM-141 - BAHAMAS BLUE 1X1	HM-210 - ROYAL BLUE 2X2	HM-310 - SAPPHIRE 3X3
HM-109 - BLACK 1X1	HM-143 - ALT BLUE 1X1	HM-213 - TERRA BLUE 2X2	HM-313 - TERRA BLUE 3X3
HM-110 - ROYAL BLUE 1X1	HM-144 - PACIFIC BLUE 1X1	HM-220 - ELECTRIC BLUE 2X2	HM-320 - ELECTRIC BLUE 3X3
HM-113 - TERRA BLUE 1X1	HM-145 - MALIBU BLUE 1X1	HM-305 - MARBLED BLUE 3X3	HM-340 - NAVY BLUE 3X3
HM-120 - ELECTRIC BLUE 1X1	HM-205 - MARBLED BLUE 2X2	HM-306 - COBALT BLUE 3X3	RM-130 - BISCAYNE BAY 1X1
HM-124 - SKY BLUE 1X1	HM-206 - COBALT BLUE 2X2	HM-105 - MARBLED BLUE 1X1	RM-132 - BLUE PEARL 1X1
HM-140 - NAVY BLUE 1X1	HM-209 - BLACK 2X2	HM-309 - BLACK 3X3	

Conditions: New tiles sent to TILE INSTITUTE of AMERICA in sealed manufacturer's boxes from client above and selected at random.

## Report of Test

### STAIN RESISTANCE (T-72)

Standard Test Method for Stain Resistance of Ceramic Tile. This method provides the means for establishing whether this tile can resist staining from six commonly used materials, which may appear in tile specifications. The tile samples were prepared as per specifications with the common household materials (each material having one sample covered with a Petri dish and the other uncovered) and left for 24 hours, and then cleaned with Ajax Industrial Cleaner and water.


### Observation of Surface Stain

<u>Sample Tiles</u>	<u>Staining Materials</u>	<u>Uncovered</u>	<u>Covered</u>
1.	Coca Cola	No Stain	No Stain
2.	Lemon Juice	No Stain	No Stain
3.	Mustard	No Stain	No Stain
4.	Bacon Grease	No Stain	No Stain
5.	Catsup	No Stain	No Stain
6.	Wesson Oil	No Stain	No Stain

**Requirements:** When tested as described. No evidence of any surface stain remaining, and all traces of the staining materials can be washed from the tile's surface.

Test Results: **Pass**

Sincerely,

Handwritten signature of Gerald M. Halweg in black ink.

Gerald M. Halweg, CTC, CSI, TTA. Date: July 1, 2021  
President/CEO of TILE INSTITUTE of AMERICA