



## TILE INSTITUTE of AMERICA

23825 15<sup>th</sup> Avenue SE #149, Bothell, WA 98021 § 240 Makee Road, Penthouse-B, Honolulu, Hawaii 96815  
(805) 444-(TILE) 8453 [DoctorTile@aol.com](mailto:DoctorTile@aol.com) or [DoctorTile1@gmail.com](mailto:DoctorTile1@gmail.com)

TIA's Client: 20260406 Chemical Resistance  
April 23, 2026

Aquabella/Main Street Art, Inc.  
Mr. Brett Streadbeck and Mr. Brian L. Streadbeck  
11906 Brittmoore Park Dr.  
Houston, TX 77041

Telephone: (833) 985-2955  
[info@aquabellatile.com](mailto:info@aquabellatile.com)

Tile: SUMMIT Series (Item Description & Tile Color Name) Factory A-30. Nominal size: Porcelain.

- HORIZON 6"x18"
- RIDGE 6"x18"
- SNOWCAP 6"x18"

Conditions: New tiles were sent to Tile Institute of America, from client above, and selected at random.

**TEST CONDUCTED: Resistance of Tile to Chemical Substances (ASTM C650)**

**Procedure:** This test method covers a procedure for determining whether, and to what degree, tiles are affected by prolonged exposure to chemical substances (10% Hydrochloric Acid & 10% Potassium Hydroxide). The temperature was controlled at 75±5 ° F (24±3 ° C) with an exposure time of 24 hours.

**Requirements:** ANSI A 137.1 (General). When tested as described in ASTM C 650, the Tile shall **not** be affected.

The tile types and categories listed above yielded test values compliant with Industry's requirements.

**Testing Results: All Passed**

Sincerely,

Gerald M. Halweg, M.Ed., CTC, CSI, TTA.  
President/CEO of TILE INSTITUTE of AMERICA